



Operation manual


Wireless Remote Controller Kit

BRC7EA628 BRC7EA629 BRC7EA630 BRC7EA631 BRC7EA632



1-3 COOL/HEAT CHANGEOVER REMOTE CONTROL SWITCH





2

1

1

CONTENTS

Safety precautions	1
Handling of wireless remote controller.	5
Operation range	6
Operation procedure	6
Not malfunction of the air conditioner	13
How to diagnose trouble spots	13
Disposal requirements	15

Thank you for purchasing this Daikin optional accessory. Carefully read this operation manual before using the optional accessory. It will tell you how to use the unit properly and help you if any trouble occurs. After reading the manual, file it away for future reference.

PRIOR TO USE

This operation manual is exclusively for instructions on how to use the wireless remote controller.

Read also the operation manual attached to the indoor unit for safe usage of the system and maintenance.

1. Safety precautions

To gain full advantage of the air conditioner's functions and to avoid malfunction due to mishandling, we recommend that you read this instruction manual carefully before use. This air conditioner is classified under "appliances not accessible to the general public".

The precautions described herein are classified as WARNING and CAUTION. They both contain important information regarding safety. Be sure to observe all precautions without fail.

- WARNING Failure to follow these instructions properly may result in personal injury or loss of life.
- CAUTION Failure to observe these instructions properly may result in property damage or personal injury, which may be serious depending on the circumstances.

After reading, keep this manual in a convenient place so that you can refer to it whenever necessary. If the equipment is transferred to a new user, be sure to hand over the manual as well.

– 🕂 warning -

Be aware that prolonged, direct exposure to cool or warm air from the air conditioner, or to air that is too cool or too warm can be harmful to your physical condition and health.

When the air conditioner is malfunctioning (giving off a burning odor, etc.) turn off power to the unit and contact your local dealer.

Continued operation under such circumstances may result in a failure, electric shocks or fire hazards.

Consult your local dealer to install your equipment.

Doing the work yourself may result in water leakage, electric shocks or fire hazards.

Consult your local dealer regarding modification, repair and maintenance of the air conditioner or the remote controller. Improper workmanship may result in water leakage, electric shocks or fire hazards.

Do not place objects, including rods, your fingers, etc., in the air inlet or outlet. Injury may result due to contact with the air conditioner's high-speed fan blades.

Beware of fire in case of refrigerant leakage.

If the air conditioner is not operating correctly, i.e. not generating cool or warm air, refrigerant leakage could be the cause. Consult your dealer for assistance. The refrigerant within the air conditioner is safe and normally does not leak. However, in the event of a leakage, contact with a naked burner, heater or cooker may result in generation of noxious gas.

Do not use the air conditioner any longer until a qualified service person confirms that the leakage has been repaired.

Consult your local dealer regarding what to do in case of refrigerant leakage.

When the air conditioner is to be installed in a small room, it is necessary to take proper measures so that the amount of any leaked refrigerant does not exceed the concentration limit in the event of a leakage. Otherwise, this may lead to an accident due to oxygen depletion.

Contact professional personnel about attachment of accessories and be sure to use only accessories specified by the manufacturer.

If a defect results from your own workmanship, it may result in water leaks, electric shock or fire.

Consult your local dealer regarding relocation and re-installation of the air conditioner.

Improper installation work may result in leakage, electric shocks or fire hazards.

Be sure to use fuses with the correct ampere reading.

Do not use improper fuses, copper or other wires as a substitute, as this may result in electric shock, fire, injury or damage to the unit.

Be sure to install an earth leakage breaker.

Failure to install an earth leakage breaker may result in electric shocks or fire.

Be sure to earth the unit.

Do not earth the unit to a utility pipe, lightning conductor or telephone earth lead. Imperfect earthing may result in electric shocks or fire.

A high surge current from lightning or other sources may cause damage to the air conditioner.

Consult the dealer if the air conditioner submerges owing to a natural disaster, such as a flood or typhoon.

Do not operate the air conditioner in that case, otherwise a malfunction, electric shock, or fire may result.

Do not start or stop operating the air conditioner with the power supply breaker turned ON or OFF.

Otherwise, fire or water leakage may result. Furthermore, the fan will rotate abruptly if power failure compensation is enabled, which may result in injury.

Do not use the product in the atmosphere contaminated with oil vapor, such as cooking oil or machine oil vapor.

Oil vapor may cause crack damage, electric shocks, or fire.

Do not use the product in places with excessive oily smoke, such as cooking rooms, or in places with flammable gas, corrosive gas, or metal dust. Using the product in such places may cause fire or product failures.

Do not use flammable materials (e.g., hairspray or insecticide) near the product.

. Do not clean the product with organic solvents such as paint thinner.

The use of organic solvents may cause crack damage to the product, electric shocks, or fire.

Be sure to use a dedicated power supply for the air conditioner.

The use of any other power supply may cause heat generation, fire, or product failures.

Do not use the air conditioner for purposes other than those for which it is intended.

Do not use the air conditioner for cooling precision instruments, food, plants, animals or works of art as this may adversely affect the performance, quality and/or longevity of the object concerned.

Do not place objects that are susceptible to moisture directly beneath the indoor or outdoor units.

Under certain conditions, condensation on the main unit or refrigerant pipes, air filter dirt or drain blockage may cause dripping, resulting in fouling or failure of the object concerned.

To avoid oxygen depletion, ensure that the room is adequately ventilated if equipment such as a burner is used together with the air conditioner.

After prolonged use, check the unit stand and its mounts for damage.

If left in a damaged condition, the unit may fall and cause injury.

Do not place flammable sprays or operate spray containers near the unit as this may result in fire.

Before cleaning, be sure to stop unit operation, turn the breaker off or remove the power cord.

Otherwise, an electric shock and injury may result.

To avoid electric shocks, do not operate with wet hands.

Do not place appliances that produce naked flames in places exposed to the air flow from the unit as this may impair combustion of the burner.

Do not place heaters directly below the unit, as resulting heat can cause deformation.

Do not allow a child to mount on the outdoor unit or avoid placing any object on it.

Falling or tumbling may result in injury.

Do not block air inlets nor outlets. Impaired air flow may result in insufficient performance or trouble.

Be sure that children, plants or animals are not exposed directly to airflow from the unit, as adverse effects may ensue.

Do not wash the air conditioner or the remote controller with water, as this may result in electric shocks or fire.

Do not place water containers (flower vases, etc.) on the unit, as this may result in electric shocks or fire.

Do not install the air conditioner at any place where there is a danger of flammable gas leakage.

In the event of a gas leakage, build-up of gas near the air conditioner may result in fire hazards.

Do not put flammable containers, such as spray cans, within 1 m from the blow-off mouth.

The containers may explode because the warm air output of the indoor or outdoor unit will affect them.

The batteries must be removed from the appliance before it is scrapped and they are disposed of safely.

Arrange the drain to ensure complete drainage.

If proper drainage from the outdoor drain pipe does not occur during air conditioner operation, there could be a blockage due to dirt and debris build-up in the pipe. This may result in a water leakage from the indoor unit. Under these circumstances, stop air conditioner operation and consult your dealer for assistance.

The appliance is not intended for use by unattended young children or infirm persons.

Impairment of bodily functions and harm to health may result.

Children should be supervised to ensure that they do not play with the unit or its remote controller.

Accidental operation by a child may result in impairment of bodily functions and harm health.

Do not let children play on or around the outdoor unit.

If they touch the unit carelessly, injury may be caused.

Consult your dealer regarding cleaning the inside of the air conditioner. Improper cleaning may cause breakage of plastic parts, water leakage and other damage as well as electric shocks.

To avoid injury, do not touch the air inlet or aluminum fins of the unit.

Do not place objects in direct proximity of the outdoor unit and do not let leaves and other debris accumulate around the unit.

Leaves are a hotbed for small animals which can enter the unit. Once in the unit, such animals can cause malfunctions, smoke or fire when making contact with electrical parts.

Never touch the internal parts of the controller.

Do not remove the front panel. Touching certain internal parts will cause electric shocks and damage to the unit. Please consult your dealer about checking and adjustment of internal parts.

wi If the da W tre in	o not leave the remote controller herever there is a risk of wetting. water gets into the remote controller ere is a risk of electrical leakage and image to electronic components. hen using the wireless remote con- oller, do not put a strong light beam or stall an inverter fluorescent lamp near e receiving section on the main unit.	7	DISPLAY " 诊 TEST " (INSPECTION/ TEST OPERATION) When the INSPECTION/TEST OPER- ATION BUTTON is pressed, the dis- play shows currently set mode. ON/OFF BUTTON Press the button and the system will					
A	malfunction may occur.	0	start. Press the button again and the system will stop.					
te Hi ut	atch your steps at the time of air fil- r cleaning or inspection. gh-place work is required, to which most attention must be paid. the scaffold is unstable, you may fall or pple down, thus causing injury.	9	FAN SPEED CONTROL BUTTON Press this button to select the fan speed, HIGH/LOW (BRC7EA628/29) or HIGH/ MEDIUM/LOW (BRC7EA630, BRC7EA631, BRC7EA632) of your choice.					
2.	Names and functions of the operating section (Fig. 1, 2)	10	TEMPERATURE SETTING BUTTON Use this button for SETTING TEM- PERATURE (Operates with the front cover of the remote controller closed.)					
1	DISPLAY "▲" (SIGNAL TRANSMISSION) This lights up when a signal is being transmitted.	11	PROGRAMMING TIMER BUTTON Use this button for programming "START and/or STOP" time. (Operates with the front cover of the remote con-					
	DISPLAY "🍫 " "💽 " " 🚖 " " 🔆 " " 🌦 " (OPERATION MODE)	40	troller opened.) TIMER MODE START/STOP BUTTON					
2	This display shows the current OPER- ATION MODE. For cooling only type, " (▲) " (Auto) and " ※" (Heating) are	12 13	Refer to page 9. TIMER RESERVE/CANCEL BUTTON Refer to page 10.					
	not installed. DISPLAY " 구종 " (SET TEMPERATURE)	14	AIR FLOW DIRECTION ADJUST BUTTON Refer to page 8.					
3	This display shows the set temperature.	15	OPERATION MODE SELECTOR BUTTON Press this button to select OPERA-					
4	DISPLAY " hr. ๏ · ๋๋ hr. ๏ · ๋่ " (PROGRAMMED TIME)		TION MODE. FILTER SIGN RESET BUTTON					
4	This display shows PROGRAMMED TIME of the system start or stop.	16	Refer to the section of MAINTENANCE in the operation manual attached to the indoor unit.					
5	DISPLAY " 나는 " (AIR FLOW FLAP) Refer to page 9.	47	INSPECTION/TEST OPERATION BUTTON					
6	DISPLAY " 论 " (FAN SPEED) The display shows the set fan speed.	17	This button is used only by qualified ser- vice persons for maintenance purposes.					
L		18	EMERGENCY OPERATION SWITCH This switch is readily used if the remote controller does not work.					


	RECEIVER												
19	This receives the signals from the												
	remote controller.												
	OPERATING INDICATOR LAMP (Red)												
20	This lamp stays lit while the air												
20	conditioner runs. It flashes when the												
	unit is in trouble.												
21	TIMER INDICATOR LAMP (Green)												
21	This lamp stays lit while the timer is set.												
	AIR FILTER CLEANING TIME												
22	INDICATOR LAMP (Red)												
22	Lights up when it is time to clean the air												
	filter.												
1	DEFROST LAMP (Orange)												
23	Lights up when the defrosting opera-												
20	tion has started. (For cooling only type												
	this lamp does not turn on.)												
	FAN/AIR CONDITIONING SELECTOR												
24	SWITCH												
	Set the switch to " 🐶 " (FAN) for FAN												
	and " 🗊 " (A/C) for HEAT or COOL.												
	COOL/HEAT CHANGEOVER SWITCH												
25	Set the switch to " 🗱 " (COOL) for												
	COOL and " 🔅 " (HEAT) for HEAT.												
	For the sake of explanation, all indica-												
	ions are shown on the display in Figure 1												
	contrary to actual running situations.												
	Fig. 1-2 shows the remote controller with												
	he front cover opened.												
	Fig. 1-3 shows this remote controller can												
	be used in conjunction with the one pro-												
	vided with the VRV system.												
	f the air filter cleaning time indicator lamp												
	ights up, clean the air filter as explained												
	n the operation manual provided with the												
	ndoor unit.												
A	ndoor unit. After cleaning and reinstalling the air fil-												
/ t	ndoor unit. After cleaning and reinstalling the air fil- er, press the filter sign reset button on												
/ t	ndoor unit. After cleaning and reinstalling the air fil- er, press the filter sign reset button on he remote controller. The air filter clean-												
۲ t t	ndoor unit. After cleaning and reinstalling the air fil- er, press the filter sign reset button on he remote controller. The air filter clean- ng time indicator lamp on the receiver												
۲ t ii v	ndoor unit. After cleaning and reinstalling the air fil- er, press the filter sign reset button on he remote controller. The air filter clean-												

3. Handling of wireless remote controller

Precautions in handling remote controller

Direct the transmitting part of the remote controller to the receiving part of the air conditioner.

If something blocks the transmitting and receiving path of the indoor unit and the remote controller, such as curtains, it will not operate.



2 short beeps from the receiver indicates that the transmission is properly done. Transmitting distance is approximately 7 m.

Do not drop or get it wet. It may get damaged.

Never press the button of the remote controller with a hard, pointed object.

The remote controller may get damaged.

Installation site

- It is possible that signals will not be received in rooms that have electronic fluorescent lighting. Please consult with the salesman before buying new fluorescent lights.
- If the remote controller operated some other electrical apparatus, move that machine away or consult your dealer.

Placing the remote controller in the remote controller holder

Install the remote controller holder to a wall or a pillar with the attached screws. (Make sure it transmits)

Placing the remote controller

Removing the remote controller

Pull it upward

Slide from above





How to put the dry batteries

- (1) Remove the back cover of the remote controller to the direction pointed by the arrow mark.
- (2) Put the batteries Use two dry cell batteries (AAA.LR03 (alkaline)). Put dry batteries correctly to fit their (+) and (-).





(3) Close the cover.

- When to change batteries

Under normal use, batteries last about a year. However, change them whenever the indoor unit doesn't respond or responds slowly to commands, or if the display becomes dark.

[CAUTION]

- Replace all batteries at the same time, do not use new and old batteries simultaneously.
- · In case the remote controller is not used for a long time take out all batteries in order to prevent liquid leak of the battery.

IN CASE OF CENTRALIZED CONTROL SYSTEM

If the indoor unit is under centralized control, it is necessary to switch the remote controller's settina.

In this case, contact your DAIKIN dealer.

Operation range 4.

VRV and Sky Air System

See the operation manual provided with the air conditioner.

Operation procedure 5.

- Refer to figure 1 on page [1]
- Operating procedure varies with heat pump type and cooling only type. Contact your Daikin dealer to confirm your system tvpe.
- To protect the unit, turn on the main power switch 6 hours before operation.
- · If the main power supply is turned off during operation, operation will restart automatically after the power turns back on again.

COOLING, HEATING, AUTOMATIC, FAN, AND PROGRAM DRY **OPERATION**

Operate in the following order.

- AUTOMATIC OPERATION can be selected only by Heat pump split system or Heat recovery VRV system.
- For cooling only type, "COOLING", and "FAN" and "DRY" operation are available to select.

(FOR SYSTEMS WITHOUT COOL/ HEAT CHANGEOVER REMOTE CONTROL SWITCH

Refer to figure 1-1, 2 on page [1]



OPERATION MODE SELECTOR

Press OPERATION MODE SELECTOR button several times and select the

OPERATION MODE of your choice as follows.

- COOLING OPERATION" * "
- AUTOMATIC OPERATION" 🔂 "
 - In this operation mode, COOL/HEAT changeover is automatically conducted.
- FAN OPERATION" 🍫 "
- DRY OPERATION" 💽 "
 - The function of this program is to decrease the humidity in your room with the minimum temperature decrease.
 - Micro computer automatically determines TEMPERATURE and FAN SPEED.
 - This system does not go into operation if the room temperature is below 16°C.



Press ON/OFF button

OPERATION lamp lights up or goes off and the system starts or stops OPERATION.

NOTE -

 Do not turn OFF power immediately after the unit stops. Then, wait no less than 5 minutes.

Water may leak or other problems may occur.

$\langle\langle \text{FOR SYSTEMS WITH COOL/HEAT} \right.$ Changeover remote control switch $\rangle\rangle$

Refer to figure 1-1,3 on page [1]



OPERATION MODE

(1) Select OPERATION MODE with the COOL/HEAT CHANGEOVER REMOTE CONTROL SWITCH as follows.

■ COOLING OPERATION



- FAN OPERATION " (Segme "

• See "FOR SYSTEM WITHOUT COOL/ HEAT CHANGEOVER REMOTE CONTROL SWITCH" for details on dry operation.

(2) Press OPERATION MODE SELECTOR button several times and select " I " (This operation is only available during dry operation.)



Press ON/OFF button

OPERATION lamp lights up or goes off and the system starts or stops OPERATION.

NOTE

• Do not turn OFF power immediately after the unit stops. Then, wait no less than 5 minutes.

Water may leak or other problems may occur.

[EXPLANATION OF HEATING OPERATION] DEFROST OPERATION

- As the frost on the coil of an outdoor unit increases, heating effect decreases and the system goes into DEFROST OPERATION.
- The fan operation stops and the DEFROST lamp of the indoor unit goes on. After 6 to 8 minutes (maximum 10 minutes) of DEFROST OPERATION, the system returns to HEATING OPERATION.

Heating capacity & Outdoor air temperature

• Heating capacity drops as outdoor air temperature lowers. If feeling cold, use another heater at the same time as this air conditioner.

- Hot air is circulated to warm the room. It will take some time from when the air conditioner is first started until the entire room becomes warm. The internal fan automatically turns at low speed until the air conditioner reaches a certain temperature on the inside. Wait until the temperature in the room reach desired temperature.
- If hot air accumulates on the ceiling and feet are left feeling cold, it is recommended to use a circulator. For details, contact the place of purchase.

ADJUSTMENT

For programming TEMPERATURE, FAN SPEED and AIR FLOW DIRECTION, follow the procedure as shown in following illustration.



TEMPERATURE SETTING

Press TEMPERATURE SETTING button and program the setting temperature.



Each time this button is pressed, setting temperature rises 1°C.

Each time this button is pressed, setting temperature lowers 1°C.



In case of automatic operation

Each time this button is pressed, setting temperature shifts to "H" side.

Each time this button is pressed, setting temperature shifts to "L" side.

[°C]

					1 -1
	Н		М		L
Setting temperature	25	23	22	21	19

• The setting is impossible for fan operation.

NOTE -

• The setting temperature range of the remote controller is 16°C to 32°C.



FAN SPEED CONTROL

Press FAN SPEED CONTROL button.

High or Low fan speed can be selected (BRC7EA628/29).

High, Medium or Low fan speed can be selected (BRC7EA630, BRC7EA631, BRC7EA632).

The microchip may sometimes control the fan speed in order to protect the unit.



AIR FLOW DIRECTION ADJUST

Press the AIR FLOW DIRECTION ADJUST button to select the air direction as shown in following illustration.



DISPLAY appears and the air flow direction continuously varies (automatic swing setting).


Press AIR FLOW DIREC-TION ADJUST button to select the air direction of your choice.



DISPLAY vanishes and the air flow direction is fixed (Fixed air flow direction setting).

Adjusting left/right air flow direction

Angle the flaps to the left/right from the knob, as wanted or as needed to air condition the room.



NOTE -

 Stop flaps from swinging before trying to angle them. Working while the flaps are moving may get your fingers pinched.

MOVEMENT OF THE AIR FLOW FLAP

For the following conditions, micro computer controls the air flow direction so it may be different from the display.

Operation mode	Cooling	Heating
Operation conditions	• When operating continuously at downward air flow direction	 When room temperature is higher than the set temperature At defrost operation (The flaps blow horizontally to avoid blowing cold air directly on the occupants of the room.)

NOTE

- If you try cooling or programmed drying while the flaps are facing downward, air flow direction may change unexpectedly. There is nothing wrong with the equipment. This serves to prevent dew formed on parts in the air discharge outlet from dripping.
- Operation mode includes automatic operation.

PROGRAM TIMER OPERATION

Operate in the following order.

• The timer is operated in the following two ways.

Programming the stop time $(\bigcirc \cdot \bigcirc)$ The system stops operating after the set time has elapsed.

Programming the start time (⊕ · |)

.... The system starts operating after the set time has elapsed.

- The timer can be programmed a maximum of 72 hours.
- The start and the stop time can be simultaneously programmed.



Press the TIMER MODE START/STOP button several times and select the mode on the display.

The display flashes.

For setting the timer stop " \bigcirc " \bigcirc " For setting the timer start " \bigcirc "



Press the PROGRAMMING TIME button and set the time for stopping or starting the system.

When this button is pressed, the time setting advances by 1 hour.

When this button is pressed, the time setting goes backward by 1 hour.





Press the TIMER RESERVE button.

The timer setting procedure ends. The display changes from flashing light to a constant light.



Press the TIMER OFF button to cancel programming. The display vanishes.

For example.



When the timer is programmed to stop the system after 3 hours and start the system after 4 hours, the system will stop after 3 hours and then 1 hour later the system will start.

NOTE


• After the timer is programmed, the display shows the remaining time.

HOW TO SET MASTER REMOTE CONTROLLER (For VRV system)

• When the system is installed as shown in the following picture, it is necessary to designate the master remote controller.

For Heat pump system


When one outdoor unit is connected with several indoor units.



One of these remote controllers needs to be designated as the master remote controller.

For Heat recovery system

When one BS unit is connected with several indoor units.



One of these remote controllers needs to be designated as the master remote controller.

 Only the master remote controller can select HEATING, COOLING or AUTOMATIC (only Heat recovery system) OPERATION.

When the indoor unit with master remote controller is set to "COOL", you can switch over operation mode between "FAN", "DRY" and "COOL".

When the indoor unit with master remote controller is set to "HEAT", you can switch over operation mode between "FAN" and "HEAT". When the indoor unit with master remote controller is set to "FAN", you cannot switch operation mode.

When attempting settings than those consented above, a "beep" is emitted as a warning.

Only with Heat recovery system, you can set the indoor unit to AUTOMATIC. Attempting to do so, a "beep" will be emitted as a warning.

How to designate the master remote controller

Operate in the following order.



Continuously press the OPERATION MODE SELECTOR button for 4 seconds.

The displays showing " \oplus " of all slave indoor units connected to the same outdoor unit or BS unit will flash.



Press the OPERATION MODE SELEC-TOR button to the indoor unit that you wish to designate as the master remote controller. Then designation is completed. This indoor unit is designated as the master remote controller and the display showing " ⊕ " vanishes.

• To change settings, repeat steps 1 and 2.

EMERGENCY OPERATION


When the remote controller does not work due to battery failure or the absence thereof, use this switch which is located beside the discharge grille on the main unit. When the remote controller does not work, but the battery low indicator on it is not lit, contact your dealer.

[START]



Press the emergency operation switch.

The machine runs in the previous mode. The system operates with the previously set air flow direction.



[STOP]



Press the EMERGENCY OPERATION switch again.

PRECAUTIONS FOR GROUP CONTROL SYSTEM OR TWO REMOTE CONTROLLERS CONTROL SYSTEM

This system provides two other control systems beside individual control (one remote controller controls one indoor unit) system. Confirm the following if your unit is of the following control system type.

Group control system

One remote controller controls up to 16 indoor units.

All indoor units are equally set.

■ Two remote controllers control system Two remote controllers control one indoor unit (in case of group control system, one group of indoor units).

The unit follows individual operation.

NOTE -

- Cannot have two remote controller control system with only wireless remote controllers. (It will be a two remote controller control system having one wired and one wireless remote controllers.)
- Under two remote controllers control system, wireless remote controller cannot control timer operation.
- During operation of the two controllers connected the same unit, the wireless remote controller displays the OPERA-TION MODE only.
- If the wired remote controller is used for operation, the display on the wireless remote controller does not change.
- Only the operating indicator lamp out of 3 other lamps on the indoor unit display functions.

NOTE -

 Contact your Daikin dealer in case of changing the combination or setting of group control and two remote controller control systems.

6. Not malfunction of the air conditioner

The following symptoms do not indicate air conditioner malfunction

I. THE SYSTEM DOES NOT OPERATE

- The system does not restart immediately after the ON/OFF button is pressed. If the OPERATION lamp lights, the system is in normal condition. It does not restart immediately because a safety device operates to prevent overload of the system. After 5 minutes, the system will turn on again automatically.
- The system does not restart immediately when TEMPERATURE SETTING button is returned to the former position after pushing the button.

It does not restart immediately because a safety device operates to prevent overload of the system. After 5 minutes, the system will turn on again automatically.

 If the reception beep is rapidly repeated 3 times (it sounds only twice when operating normally).

Control is set to the optional controller for centralized control.

• If the defrost lamp on the indoor unit's display is lit when heating is started. This indication is to warn against cold air being blown from the unit. There is nothing wrong with the equipment.

7. How to diagnose trouble spots

I. EMERGENCY STOP

When the air conditioner stops in emergency, the run lamp on the indoor unit starts blinking. Take the following steps yourself to read the malfunction code that appears on the display. Contact your dealer with this code. It will help pinpoint the cause of the trouble, speeding up the repair.



Press the INSPECTION/TEST button to select the inspection mode " $\frac{1}{2}$ ".

" 🚺 " appears on display and blinks. "UNIT no." lights up.



Press PROGRAMMING TIMER BUT-TON and change the unit number.

Press to change the unit number until the indoor unit beeps and perform the following operation according to the number of beeps.

Number of beeps

3 short beepsPerform all steps from 3

to **6**.

1 short beepPerform **3** and **6** steps 1 long beepNormal state

Press OPERATION MODE SELECTOR BUTTON.

" $\hfill J$ " on the left-hand of the malfunction code blinks.



Press PROGRAMMING TIMER BUT-TON and change the malfunction code.

Press until the indoor unit beeps twice.



Press OPERATION MODE SELECTOR BUTTON.

" <u>[</u>] " on the right-hand of the malfunction code blinks.



Press PROGRAMMING TIMER BUT-TON and change the malfunction code.


Press until the indoor unit makes a long beep.

The malfunction code is fixed when the indoor unit makes a long beep.



Reset of the display


Press OPERATION MODE SELECTOR BUTTON to get the display back to the normal state.



II. IN CASE BESIDES EMERGENCY STOP

1. The unit does not operate at all.

- Check if the receiver is exposed to sunlight or strong light. Keep the receiver away from the light.
- Check if there are batteries in the remote controller. Insert the batteries if they are missing.
- Check if the indoor unit number and wireless remote controller number are equal.



Operate the indoor unit with the remote controller of the same number.

Signal transmitted from a remote controller of a different number cannot be accepted. (If the number is not mentioned, it is considered as "1")

- 2. The system operates but it does not sufficiently cool or heat.
 - If the set temperature is not proper.
 - If the FAN SPEED is set to LOW SPEED.
 - If the air flow angle is not proper.


Contact the place of purchase in the following case.

- 🕂 WARNING

When you detect a burning odor, shut OFF power immediately and contact the place of purchase. Using the equipment in anything but proper working condition can result in equipment damage, electric shock and/or fire.

[Trouble]

The RUN lamp of the indoor unit is flashing and the unit does not work at all.



[Remedial action]

Check the malfunction code (A1 - UF) on the remote controller and contact the place of purchase. (See page 12.)

8. Disposal requirements

Your product and the batteries supplied with the controller are marked with this symbol. This symbol means that electrical and electronic products and



batteries shall not be mixed with unsorted household waste. For batteries, a chemical symbol can be printed beneath the symbol. This chemical symbol means that the battery contains a heavy metal above a certain concentration. Possible chemical symbols are:

■ Pb: lead (>0.004%)

Do not try to dismantle the system yourself. The dismantling of the product, treatment of the refrigerant, of oil and of other parts must be done by a qualified installer in accordance with relevant local and national legislation. Units and waste batteries must be treated at a specialized treatment facility for re-use, recycling and recovery. By ensuring correct disposal, you will help to prevent potential negative consequences for the environment and human health. Please contact the installer or local authority for more information.



_		_	_	_		_		_	_	_	_	_	_	 _	_		 _	_	_	_
															_	 	 			
	-	-			-										_	 	 			
\vdash		<u> </u>																		
		-					 							 		 	 			
\vdash		-					 							 		 	 	-		
	-	-				-														
\vdash																				



_		_	_	_		_		_	_	_	_	_	_	 _	_		 _	_	_	_
	-	-			-										_	 	 			
\vdash		<u> </u>																		
		-					 							 		 	 			
\vdash		-					 							 		 	 			
	-	-				-														
\vdash																				



 	 		_	 _	 _	 _	_	_	_	_	
				 		 _	 				
	_			 	 	 _	 				
				 		 _					
	 	-		 	 _	 _	 		-		
	_			 	 	 _	 		_		
	_					 -	 	-			
	 _			 	 	 _	 		-		
				 		 _		-			
	_			 	 	 _	 		-		
	_					 _	 				
	_					_					
	_					 -	 	-			
	_			 	 	 _	 				

DAIKIN EUROPE N.V.

Zandvoordestraat 300, B-8400 Oostende, Belgium

3P505118-3C 2021.06