

## 6 Dimensional drawing & centre of gravity

### 6 - 1 Dimensional drawing

**FXMLQ100,125P**

**NOTES**

- Location of MANUFACTURE'S LABEL: Control box surface
- Mount the air filter at the suction side. (Select its color method (gravity method) 50% or more)
- Do not locate things should not be wet under the indoor unit. Dews may droop when humidity reaches over 80%, or a drain gets stuck, or air filters are not clean.
- Space for Service Works  
According to any one of below 1) - 3), secure a space for service works, such as, checking and maintenance of control box and drain pumps, etc.
  - 1) One inspection hatch (450x450) on the control box side and a space of 300mm or more under the unit. (Fig.A)
  - 2) One inspection hatch (450x450) on the control box side and 2 (two) inspection hatches under the unit (Arrow view B-1)
  - 3) 3 (three) inspection hatches under the unit and the control box. (Arrow view B-2)

ITEM	PART NAME	REMARK
12	Drain hose (accessory)	O.D. ø 32 (outlet)
11	Socket (for maintenance)	VP25 (O.D. ø 32 / I.D. ø 25)
10	Hook	For M10
9	Air suction flange	
8	Air discharge flange	
7	Power supply connection	
6	Interunit wiring connection	
5	Control box (inside)	
4	Ground terminal (in control box)	M4
3	Drain pipe connection	VP25 (O.D. ø 32 / I.D. ø 25)
2	Gas pipe connection	ø 15.9 flate connection
1	Liquid pipe connection	ø 9.5 flate connection

6

3D060162

DAIKIN • VRV®systems • Indoor Units

11