

Splits with Wired Remote

The need for the EKRS21 for installation with BRC073


The EKRS21 wire harness helps establish a successful connection between the S21 connector located inside the PCB of the Stylish Range, the new Standard Inverter and new Floor unit. It is essential to have this cable available especially when a wired remote controller BRC073 is going to be installed.

To enable a successful connection between the **BRC073** and the fan coil unit, the connection cable (**BRCW901A0***) and the **EKRS21** cable are needed. Both **need to be ordered separately**. The EKRS21 converts the connector to a smaller size in order to fit into the S21 port situated within the fan coil.



Figure 1 EKRS21 Cable

Material needed:



Model Reference:

This applies to the following model references

- ✓ Stylish - C/FTXA-AW/BS/BT/BB
- ✓ Standard Inverter – C/FTXM-R
- ✓ Unified Floor – C/FVXM-A

The present leaflet is drawn up by way of information only and does not constitute an offer binding upon Daikin UK. Daikin UK has compiled the content of this leaflet to the best of its knowledge. No express or implied warranty is given for the completeness, accuracy, reliability or fitness for particular purpose of its content and the products and services presented therein. Specifications are subject to change without prior notice. Daikin UK explicitly rejects any liability for any direct or indirect damage, in the broadest sense, arising from or related to the use and/or interpretation of this leaflet. All content is copyrighted by Daikin UK.

